

**Dahej SEZ Limited**

**Tender No: 01/2023-24**

**Name of Work: Tender for Appointment of agency / firm for Annual Operation & Maintenance STP (25KL) for Dahej SEZ Ltd.**

**Minutes of the Pre-bid meeting held on 19/06/2023 at 11.00 AM in the Office of The Dahej SEZ Ltd, Dahej, Ta: Vagra, Bharuch**

SN	Query raised / Clarification required	Reply / Clarification by DSL
1	Condition of filter / membrane and when it was change?	<p>It was clarified by DSL that filter / membrane did not change after installation of STP in the year 2012 since as per the feedback received from existing AMC agency life of the same is around 15 to 17 years depending up on operation &amp; Maintenance of the same.</p> <p>DSL further clarified that Agency has to visit the STP and quote the price accordingly for satisfactory functioning of Sewage treatment Plant (STP).</p>

Other Tender Terms & Conditions will be remained unchanged.

~~CEO~~

*Patel*  
*22/06/23*